

**PCM Air Sample Chain of Custody
Field Data Sheet
AREA SAMPLES**



Project Number: 47:1946-F
Abingdon Elementary School
 Project Address: Arlington, Virginia

Date: 1/24/2017
 Page: 1 of 3

Sample #	Location/Description	Start	Stop	Flow (lpm)	Total Time (min)	Volume (l)	Fibers #	Field #	Result (f/cc)
012417-01	Hallway outside Classroom 161	4:16 PM	5:36 PM	15	80	1200	13	100	0.005
012417-02	Hallway outside Classroom 162	4:19 PM	5:39 PM	15	80	1200	5.5	100	0.002
012417-03	Classroom 163	4:20 PM	5:40 PM	15	80	1200	9	100	0.004
012417-04	Classroom 164	4:23 PM	5:43 PM	15	80	1200	12	100	0.005
012417-05	Hallway outside Classroom 165	4:26 PM	5:46 PM	15	80	1200	4	100	0.002
012417-06	Lobby area outside Electrical Room 181	4:32 PM	5:52 PM	15	80	1200	10	100	0.004
012417-07	2nd Floor Sawtooth Construction Area, center	4:46 PM	6:06 PM	15	80	1200	7	100	0.003
							Notes: NFD = None Fibers Detected OWA = Outside Work Area IWA = Inside Work Area		

ECS Technician JP Nuique Time 10:00 PM Date 1/24/2017

**PCM Air Sample Chain of Custody
Field Data Sheet
AREA SAMPLES**



Project Number: 47:1946-F
Abingdon Elementary School
 Project Address: Arlington, Virginia

Date: 1/24/2017
 Page: 2 of 3

Sample #	Location/Description	Start	Stop	Flow (lpm)	Total Time (min)	Volume (l)	Fibers #	Field #	Result (f/cc)
012417-08	Library, non-fiction area	4:49 PM	6:09 PM	15	80	1200	6	100	0.002
012417-09	Classroom 165	4:56 PM	6:16 PM	15	80	1200	6	100	0.002
012417-10	Classroom 161	5:37 PM	6:57 PM	15	80	1200	4	100	0.002
012417-11	Classroom 162	5:39 PM	6:59 PM	15	80	1200	1	100	0.000
012417-12	Hallway outside Classroom 164	5:43 PM	7:03 PM	15	80	1200	11.5	100	0.005
012417-13	Library, reception desk	5:44 PM	7:04 PM	15	80	1200	13	100	0.005
012417-14	Computer Lab 200	6:07 PM	7:27 PM	15	80	1200	6	100	0.002
							Notes: NFD = None Fibers Detected OWA = Outside Work Area IWA = Inside Work Area		

ECS Technician JP Nuique Time 10:00 PM Date 1/24/2017

**PCM Air Sample Chain of Custody
Field Data Sheet
AREA SAMPLES**



Project Number: 47:1946-F
Abingdon Elementary School
 Project Address: Arlington, Virginia

Date: 1/24/2017
 Page: 3 of 3

Sample #	Location/Description	Start	Stop	Flow (lpm)	Total Time (min)	Volume (l)	Fibers #	Field #	Result (f/cc)
012417-15	Library, Fiction	8:20 PM	10:20 PM	15	120	1800	8	100	0.002
012417-16	Elevated Hallway outside computer lab	8:22 PM	10:22 PM	15	120	1800	13.5	100	0.004
012417-17	North Hallway near Classroom 134	9:14 PM	10:34 PM	15	80	1200	5	100	0.002
012417-18	Field Blank	--	--	--	--	0	0	100	NFD
012417-19	Field Blank	--	--	--	--	0	0	100	NFD
Notes: NFD = None Fibers Detected OWA = Outside Work Area IWA = Inside Work Area									

ECS Technician JP Nuique Time 10:00 PM Date 1/24/2017